

Prebid meeting for HVAC works on 24th june 2022 for the

DRT project to be executed at 4th floor, BSNL building, Rajbhavan Road, Bengaluru

TENDER REFERENCE: BLCPR:ADVSMT: 229:2022 dated 18/06/2022

Sl no	Prebid queries	Replies to the queries
01	Time of completion was sought for 75 days by vendors	Finalized the time of completion at 60 days from the date of issue of work orders
02	EMD was not stipulated	1% EMD needs to be submitted at the time of tender submission
03	Since GST is separate for item purchase and for labour , separate BOQ indicating supply and labour quotes needs to be provided	Agreed to provide
04	Providing 2 no Lower capacity is not possible.	2 compressors with adequate capacity are required for the outdoor units.
04	Approved layout is to be provided	Agreed to provide the same