1	<b>DESCRIPTION</b> Suppy, Fixing, Testing & comissioning of following star rated	QUANTITY	UNIT	RATE (Rs.)	AMOUNT (Rs.)
	117 3 3				
	AC: t: t: 1 0: :				
	AC units, with evaporator copper coil & imported refrigerant				
	joints, with wireless remote controller (Make:- LG/Bluestar /				
(i)	Voltas / Carrier Only) Cassette 2 TON - 3 Star	4.00	No.		
(ii)	Split 1.0 TON - 3 Star	4.00	No.		
(11)	3piit 1.0 1014 - 3 Stai	4.00	INO.		
	SITC of interconnecting refrigerant pipe of required dia				
	work with closed cell elastomeric nitrile rubber tublar in				
2	sulation between each set of indoor & outdoor units as per				
	specification, all piping inside the room shall be peoperly				
	supported with MS hanger & clamps including required				
	cabling from indoor to outdoor unit. (Make :- Mandev,				
/:\	Colit 1 0 TON 2 Store	60.00	Rmt		
(i)	Split 1.0 TON - 3 Star	60.00	-		
(ii)	Cassette 2.0 TON - 3 Star	60.00	Rmt		
	Providing & fixing, testing and commissioning of wall				
	mounted copper wound voltage stabilizer suitable for split				
3	all accessories.				
3	Input Voltage range : 140-280 V,				
	Output: 230 V (Make:- Blue- Bird/V guard & other				
	ronuted Firm \				
(i)	CAPACITY: 5 KVA	4.00	Nos		
(ii)	CAPACITY: 4 KVA	4.00	Nos		
4	SITC of rigid <b>CPVC piping</b> complete with fittings supports as				
	per specification tions & duly insulated with 6mm thick				
	closed cell nitrile rubber insulation.				
(i)	Drain Pipe for 2.0 Ton AC (Cassette)	75.00	Rmt		
(ii)	Drain Pipe for Split 1.0 TR (Split)	75.00	Rmt		
	M.S. stand with monkey cage with lock - [In door & out door				
5	units]	8.00	No		
6	Installation Charges .	8.00	No		
7	Digital Dual AC Switching Timer for ATM (BIS / ISI Marked)	1.00	No		
	TOTAL (Rs.)				
	<ul><li>-: All work should be done as per Bank's Specification</li><li>:: GST shall be paid extra as per Govermenment norms at tl</li></ul>		_		