



CORRIGENDUM NOTICE

In continuation to our tender notice (Ref No. CB/LCO/LF/2021-22/001 dtd 19.05.2021) for SUPPLY AND INSTALLATION OF 2 NOS. NEW 10 PASSENGER LIFTS AT CANARA BANK CIRCLE OFFICE BUILDING, VIPIN KHAND, GOMTI NAGAR, LUCKNOW, UTTAR PRADESH – 226010, the following modifications are made in the tender terms & conditions:

Tender Page No.	As per Tender document	Modifications
PART-I TECHNICAL BID Page No. 3 NOTICE INVITING TENDER (NIT) – 7) DATE OF SUBMISSION	Sealed envelopes to be submitted on or before 30.06.2021 up to 3.00 PM	Sealed envelopes to be submitted on or before <u>12.07.2021 up to 3.00 PM</u>
PART-I TECHNICAL BID Page No. 3 NOTICE INVITING TENDER (NIT) – 8) DATE OF OPENING	Technical Bid will be opened on 30.06.2021 at 3.30 PM	Technical Bid will be opened on <u>12.07.2021 at 3.30 PM</u>
PART-I TECHNICAL BID	The subordinate caption reads: "Attested Documentary proof for each	Self Attested copies of the documents shall suffice.

परिसर एवं सम्पदा अनुभाग
अंचल कार्यालय
विपिन खंड, गोमती नगर,
लखनऊ – 226010

Premises & Estate Section
Circle Office
Vipin Khand, Gomti Nagar,
Lucknow – 226010

T 0522 230 7611
E pecoluck@canarabank.com

***SIGNATURE OF THE TENDERER
WITH SEAL***

<p>Page No. 5</p> <p>ANNEXURE A – ELIGIBILITY CRITERIA</p>	<p>item is to be furnished with Tender document”.</p> <p><u>Query:</u> Whether self-attestation is sufficient or the documents are to be notarized”</p>	
<p>PART-I TECHNICAL BID</p> <p>Page No. 5</p> <p>ANNEXURE A – ELIGIBILITY CRITERIA NO. 3</p>	<p>The tenderer shall be C.P.W.D / Government approved category Lift Manufacturer. A certificate to that effect must be submitted by the bidder.</p> <p><u>Query:</u> CPWD has discontinued categorization of manufacturers of Lifts so a certificate to such effect could not be furnished by the Bidder.</p>	<p>CPWD Certificate is not mandatory. However the certificate of registration with other Government / Quasi Government / PSUs etc. can be furnished. Tenderer having registration with the above will be preferred.</p>
<p>PART-II FINANCIAL BID</p> <p>Page No. 3</p> <p>SCHEDULE OF QUANTITIES-FINANCIAL BID SL. NO. 1</p>	<p>Design, Supply, Installation, Testing and Commissioning of 10 passenger capacity lift with 2 landings (G + 1) including electrical and controls as mentioned in technical bid with necessary statutory approvals and civil works. (Rates excluding GST)</p> <p>Preferred makes are KONE, Mitsubishi, Thyssenkuup, Jhonson, Otis or equivalent make.</p> <p><u>Query:</u> The exact number of floors and landings is different in the Financial and the Technical Bid.</p>	<p>Clause to be read as: “Design, Supply, Installation, Testing and Commissioning of 10 passenger capacity lift with 4 landings (G + 3) including electrical and controls as mentioned in technical bid with necessary statutory approvals and civil works. (Rates excluding GST)</p> <p>Preferred makes are KONE, Mitsubishi, Thyssenkuup, Johnson, Otis or equivalent make”.</p> <p>TENDERERS MUST EXERCISE CARE BEFORE QUOTING THE RATE IN THE “FINANCIAL BID” FOR THIS ITEM HEAD AS THE RATE QUOTED SHALL BE</p>

		CONSIDERED FOR 4 LANDINGS (G+3) ONLY.
PART-I TECHNICAL BID Page No. 76 Schedule B SPECIAL INSTRUCTIONS TO THE TENDERER CLAUSE NO. 1.2	<p>The machine room is proposed on the terrace above the Third floor of the subject building. The proposed lift is to serve for 4 Floors (Ground floor, 1st floor, 2nd Floor, 3rd Floor) of the subject building. The tenderer shall design the equipment considering the above and the site conditions. After award of contract no claim for extra payment will be entertained.</p> <p><u>Query:</u> The proposed lift is Machine Room Less (MRL) Whether Machine Room is to be taken into consideration or Not.</p>	<p>Clause to be read as: "The proposed lift is to serve for 4 Floors (Ground floor, 1st floor, 2nd Floor, 3rd Floor) of the subject building. The tenderer shall design the equipment considering the above and the site conditions. After award of contract no claim for extra payment will be entertained."</p>
PART-I TECHNICAL BID Page No. 76 Schedule B SPECIAL INSTRUCTIONS TO THE TENDERER CLAUSE NO. 1.5.i.	<p>A general arrangement drawing indicating various dimensions, parameters, illumination and ventilation requirement, power requirement and characteristic of the elevator to be installed including load diagram and loadings to be taken into consideration in the machine room, elevator shaft and the elevator pit shall be submitted for approval of the purchaser within 2 weeks of placement of order.</p>	<p>Clause to be read as: "A general arrangement drawing indicating various dimensions, parameters, illumination and ventilation requirement, power requirement and characteristic of the elevator to be installed including load diagram and loadings to be taken into consideration in the elevator shaft and the elevator pit shall be submitted for approval of the purchaser within 2 weeks of placement of order."</p>

	<p><u>Query:</u> The proposed lift is Machine Room Less (MRL) Whether Machine Room is to be taken into consideration or Not.</p>	
<p>PART-I TECHNICAL BID</p> <p>Page No. 2</p> <p>NOTICE INVITING TENDER (NIT)</p> <p>POINT NO. 3. TIME OF COMPLETION</p>	<p>90 days commencing from the 14th day from the date of purchase order issued by the Bank.</p> <p><u>Query:</u> The time period may be extended to 7 months if units are to be replaced one by one.</p>	NO CHANGE
<p>PART-I TECHNICAL BID</p> <p>Page No. 28</p> <p>GENERAL CONDITIONS OF CONTRACT</p> <p>POINT NO. 16.2 Storage of materials</p>	<p>The contractors shall make use of existing facilities with due permission of the Employer for storage of materials at site, but watch & ward arrangements for the safety of materials shall be the responsibility of the contractor. The covered space required if any, shall be arranged at the tenderer's own cost in the open space identified/ear marked by the Bank.</p> <p><u>Query:</u> Covered storage area of 50 Sq. Mtr. Per lift shall be provided by the purchaser, it shall be locakable and weatherproof.</p>	<p>NO CHANGE.</p> <p>Only the available space in the Circle Office Building is to be effectively utilized for storage of the materials in such a manner that there is no inconvenience to the staff on a daily basis and no damage is done to the building. The covered space required if any, shall be arranged at the tenderer's own cost in the open space identified/ear marked by the Bank.</p>

PART-I TECHNICAL BID Page No. 76 Schedule B SPECIAL INSTRUCTIONS TO THE TENDERER POINT NO. 1.3	<p>All Civil alteration works inside the lift pit and the machine room, including the dismantling of the existing lift components, providing bedding to the buffer springs in the lift shaft and lift room shall be responsibility of the tenderer.</p> <p><u>Query:</u> Shaft repairing and whitewash shall be in purchaser scope.</p>	<p>NO CHANGE</p> <p>All necessary civil works and repairs are to be done by the tenderer. The rates for the same are to be quoted accordingly after duly inspecting the site conditions.</p>
PART-I TECHNICAL BID Page No. 80 Schedule B SPECIAL INSTRUCTIONS TO THE TENDERER POINT NO. 2.2.1 ELECTRICAL	<p>The scope of supply shall include all the electrical equipment / items required for smooth and efficient operation of elevator.</p> <p><u>Query:</u> The elevator can retain the existing Earthing if it works as per our standard otherwise purchaser needs to provide new double earthing.</p>	<p>NO CHANGE</p> <p>All the necessary electrical works, including providing earthing points, are to be done by the tenderer. The rates for the same are to be quoted accordingly after duly inspecting the site conditions.</p>
PART-I TECHNICAL BID Page No. 89 Schedule C Technical specifications of	<p>LIFT TYPE: MACHINE ROOM LESS (MRL)</p> <p><u>Query:</u> Existing Lifts are MR. Lifts can be replaced but customer needs to cooperate for civil works at shaft.</p>	<p>All the necessary and required civil works at site for installing a Machine Room Less (MRL) lift at site are to be done by the tenderer. The rates for the same are to be quoted accordingly after duly inspecting the site conditions.</p>



Lift		
SCOPE OF WORK		
PART-I TECHNICAL BID Page No. 98 SCOPE OF COMPREHENSIVE AMC FOR LIFT (CAMC)	<p>All the repairs and replacements of spares (Including consumables) shall be carried out which are necessitated due to usage of system as per tender stipulations. However, the repairs and replacements necessitated by loss or damage due to misuse or accident, fire or natural calamities shall be out of the scope of CAMC.</p> <p><u>Query:</u> Consumables items are not covered under AMC</p>	<p>NO CHANGE</p> <p>All items, including the consumables like light fittings, batteries and other items required & necessary for the proper functioning of all the features of the lifts are included in the scope of the CAMC. While quoting the rates for CAMC, the tenderer must factor in the usual life of the consumables when subjected to regular and uninterrupted maintenance from the tenderer. The Bank shall pay only the CAMC Charges to the vendor periodically and the vendor has to ensure that the lift and all its features are in optimum working conditions at all times.</p>

ALL THE INTENDING TENDERERS ARE REQUESTED TO TAKE NOTE OF THE MODIFICATIONS MENTIONED HITHERTO AND SUBMIT THE RESPECTIVE TENDERS ACCORDINGLY.

NOTE: SEAL-SIGNED COPIES OF ALL THE PAGES OF THIS “CORRIGENDUM NOTICE” IS TO BE SUBMITTED WITH THE “TECHNICAL BID (FIRST ENVELOPE)” FAILING WHICH THE BID SHALL BE DEEMED INCOMPLETE AND SHALL BE REJECTED.

Bank reserves the right to accept or reject any or all the tenders without assigning any reasons thereof.

-Deputy General Manager

परिसर एवं सम्पदा अनुभाग
अंचल कार्यालय
विपिन खंड, गोमती नगर,
लखनऊ – 226010

Premises & Estate Section
Circle Office
Vipin Khand, Gomti Nagar,
Lucknow – 226010

T 0522 230 7611
E pecoluck@canarabank.com

**SIGNATURE OF THE TENDERER
WITH SEAL**