

AMMENDMENT/CORRIGENDUM PRE BID QUERIES & REPLY- TENDER FOR SUPPLY AND INSTALLATION OF PASSENGER LIFT / ELEVATOR AT CIRCLE OFFICE PATNA

S NO	PAGE NO	RFP CLAUSI	RFP CLAUSE/ TECH SPECIFICATIONS IN BRIEF	BIDDERS QUERIES	BANK'S REPLY
1	4	APPENDIX 1	IMPORTANT TERMS AND CONDITION OF TENDER	Time of completion 90 days issuing of work order	90 days commencing from the 14th day from the date of purchase order issued by the Bank.
2	4	APPENDIX 1	IMPORTANT TERMS AND CONDITION OF TENDER	DLP 1 Year	1 year from the date of completion and handing over of the lift
3	4	APPENDIX 1	IMPORTANT TERMS AND CONDITION OF TENDER	LD 0.5% to 5% max of contract value	Defect liability clause will prevail as per the terms of tender document
4	4	APPENDIX 1	IMPORTANT TERMS AND CONDITION OF TENDER	TOP 75% material delivery at site with supporting docs, 20% adhoc and 5% at the end of warranty period	Payment terms clause will prevail as per the terms of contract
5	24	16.2	STORAGE OF MATERIALS	Watch & Guard in Contractors scope	The Employer on no account shall be responsible for storage of materials or loss or pilferage or theft either in respect of the material stored
6	53	1.2	Requirement of Elevator	With machine room/ without machine room	The machine room is proposed on the terrace above 8th floor
7	7	1	GENERAL RULES & GUIDANCE	B+G+9 floor, G+3+4+9 using of existing door for non operation floor	The lift to stop at ground floor, 3rd floor, 4th floor and 8th floor
8				Stone / tiles/ cladding works in scope of contractor/ employee	Stone / tiles/ cladding works in scope of contractor
9	66 B		Design Criteria	Consideration of OMEGA make lift	Make of lifts - Kone, Jhonson, Otis, Thyssenkrupp, Indo Movi Lift

All the other instructions and terms & conditions of the RFP of Elevator remain unchanged. Please take note of the above replies/ Amendments while submitting your response to the subject RFP.

DT: 06.04.2021, PLACE: PATNA

