

PREBID QUERIES AND BANK'S RESPONSE TOWARDS SUPPLY, INSTALLATION, TESTING, COMMISSIONING & MAINTENANCE OF 49 KWP CAPACITY ON GRID ROOFTOP SOLAR PV POWER PLANT AT CIBM, MANIPAL.

S.No.	Page No. In tender	Tender Clause No.	Query raised by bidder	Clarifications/Reply from the bank
1		General		The proposed capacity of the roof top solar system has been raised to 49 KWP.
2	76 of 102	Module Mounting Structure	Whether conversion of tile roof to metal roof on the top of DG rooms and Model branch room will be carried out by the bank ?	Yes, conversion of tile roof to metal roof on the top of DG rooms and Model branch room will be carried out by the bank.
3	NA	General	Whether upgradation of HT Cubicle will be carried out by the bank ?	Yes, upgradation of HT Cubicle will be carried out by the bank.
4	3 of 102	Date of submission and opening	1. Tender Response to be submitted on or before 11.08.2022, 03.00 pm. 2. Technical bid will be opened on 11.08.2022 at 3.30 PM. 3. The date for opening the price bids will be intimated subsequently only to such firms whose technical bids are found suitable.	1. Tender Response to be submitted on or before 17.08.2022, 03.00 pm. 2. Technical bid will be opened on 17.08.2022 at 3.30 PM. 3. The date for opening the price bids will be intimated subsequently only to such firms whose technical bids are found suitable.

Query