

Tender Ref. CBCO: HUB: ELCT:2/20

RESPONSES TO PRE BID QUERIES

TENDER FOR PROPOSED ELECTRICAL WORKS OF CIRCLE OFFICE AT 2ND FLOOR V2 BUILDING, PROPERTY NO. 98/4, AIRPORT ROAD, HUBBALLI-580030

Interested Bidders participated in the Pre-bid meeting for above works on 18.11.2020

Sl No	Description in tender & BOQ	Clarification Sought	Bank's Reply	Amendments in the tender, BOQ & Drawings
1	M/s Vcraft Interiors			
1	Sl no 1.1 to 1.7 in page no 15 of Technical Bid Document, Udyog Adhar - MSME Certificate.	We have attached our Udyog Adhar for your reference. Please let us know if any concern / clarifications	Please comply with point no.9, page no. 6 of technical bid document.	-No Change-
2	Sl No 2 .1 of page no 4, Technical BID, Empanelment as Electrical work contractor	We empanelled as trunkkey projects which is inclusive of Carpentry/ Furniture, Civil, Electrical , CCTV, Fire Alarm, Fire Fighting, PA System, and other related works. We can see item wise details seperately in Work order.	Bidder should have executed electrical works for the specified clients and a copy of work order / completion certificate prior to 30.09.2020 specifying the details of work can be considered for eligibility.	-No Change-
3	Sl No 2 .3 of page no 4, Technical BID, Annual average turnover.	We have more than 60 lakhs turnover of Electrical work. But since we execute trun key projects, electrical work turnover has not been seerately mentioned in BalanceSheet	Please comply with tender terms for submission of CA certificate for average turnover	-No Change-

Premises & Estate Section ,
 Circle Office Hubballi
 52A, Shanbhag Building,
 Unkal Cross, Sainagar Road,
 HUBBALLI-580031.

T: 08362-2278860 E:pecohub@canarabank.com

www.canarabank.com



4	Sl No 2.4 of page no 4, Technical BID, Work Completion Certificates	Client issued us completion certificates, but they have not mentioned work wise value seperately as we executed Turnkey projects.	Please comply with tender terms.	-No Change-
5		Require SLD to understand Electrical panel design properly	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	-No Change-
6	Part M, Sl No B 2 in page no 11 of price bid FireAlarm System	Asked for two sub Panels in Sl No. B 1 and one main control panel in Sl No B-2. Since Sub Panels what asked are conventional type, request you to clarify technical possibility of integration between sub panel and main panel.	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	-No Change-
7	Part B, Sl No b.5 in page No 5 of price bid Qty of C Channel	Qty not mentioned.	Quantity to be treated as Nil as per BOQ	-No Change-
8	Part K,Sl No K 1 page no 10, Price Bid, OHP System and TV	mentioned both Pull down and Motorised Screen models. Please clarify which one we should consider	Motorised screen model is required.	Amendment to specification in Part K, Sl no.1, Page 10 of price bid as below: Providing and Fixing screen (100" Diagonal) with black border & tubular motor driving device with less noise and smooth function.
9	Part D, Sl No D 1.7 page no 7, Price Bid, 2' X 2' Light Fittings	Please let us know how many fittings will be in Grid Ceiling and howmany will be in Gypsum ceiling.	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	-No Change-



10	Part F, Sl No. 4, Price Bid Data Supply and installation of clip on plug type telephone outlet with interconnection of the outlet. The cover plate of telephone shall match with the other wiring accessories. (Telephone socket outlet shall be of modular of type Anchor roma/equivalent)	Please confirm Voice IO shall be fix in Electrical same Box or it shall fix in separate box with plate	Please refer BOQ to be carried out as per specification of BOQ.	-No Change-
11	Part F, Sl No. 5 Data ,Supply, installation, testing & commissioning of telephone junction box. The junction box shall be with sheet steel enclosure enclosing krone connector and shall be provided with padlock	Please confirm Krone box termination shall be single Pair or two pair	Krone box termination shall be two pair as per BOQ	-No Change-
II	M/s Lakshya Electricals Pvt Ltd			
1	Page no.1, Part A, S.no. A-1 of Price Bid MV PANELS	Need to consider Fire Suppression System for the Panels of the line item nos 1.1 to 1.4	Please refer BOQ to be carried out as per specification of BOQ.	-No Change-
2	Page no.2,Part A, S.no. A-2 of Price Bid DISTRIBUTION BOARDS	Need to consider DB Frame cost along with DB	Please refer BOQ to be carried out as per specification of BOQ.	-No Change-

3	Page no.2, Part A, S.no. A-2 of Price Bid DISTRIBUTION BOARDS	Shall we consider C Curve for Ltg And RP instead of B Curve and D Curve for UPS requirement	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	-No Change-
4	Page no.4, Part B, S.no. B-2.1-2.16 of Price Bid Cable End Termination	Shall we consider Double Compression above 120 Sqmm Cable and Single Compression below 120 Sqmm cable	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	-No Change-
5		CEIG, Temporary Power Construction: Ceig and Temporary Power construction is not given in the Boq, kindly confirm	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	-No Change-
6	Page No.8, Part F, S no.F-5 of Price Bid, Telephone System	Need to consider Telephone Junction box along with Krone for the line item no F - 5	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	-No Change-
7	Page No.9, Part F ,S.no.G-6.0 of Price Bid, Data System	Confirm the Make of Network rack	D link/Net rack/ equivalent	Amendment to tender page no.96, list of approved makes for network rack is D link/Net rack/ equivalent
8	Page No.10, Part I, S.no.6 of Price Bid PA System	Need to consider conduit along with 1.5 sqmm unarmored Cable of the line item no I - 6	Cable with conduit should be considered	Amendment to price bid I (6), 1.5 Sq mm cable with suitable conduits.
9	Page No.10,Part J,S.no.1 of Price Bid CCTV System	Confirm the Makes for CCTV System	Hikivision / Dhaua / equivalent	Amendment to tender page no.96, list of approved makes for CCTV is Hikivision / Dhaua / equivalent



10	Page No.10, Part J, S.no.1&2 of Price Bid, CCTV System	The given camera is old type Analog AHD, can we consider New Model Network type	Please refer specification. Works to be carried out as per specification of BOQ.	BOQ	-No Change-
11	Page No.10, Part J, S.no.9 of Price Bid, CCTV System	CRT Monitor is not Available in the Market, Can we consider LCD Monitor	LED monitor should be considered	be	Amendment to Part J, S.no.9, page no.10 of Price Bid:
12	Page No.10, Part K, S.no.11 of Price Bid OHP System and TV	Kindly confirm the Number of Channels	Please refer specification. Works to be carried out as per specification of BOQ.	BOQ	S&L of 15" LED Monitor -No Change-
13	Page No.10, Part K, S.no.12 of Price Bid, OHP System and TV	LED TV is already given in the line item no 10. Kindly confirm	Please refer specification. Works to be carried out as per specification of BOQ.	BOQ	-No Change-
14	Page No.11, Part M, S.no.1 of Price Bid, Fire Fighting & Alarming Systems	Can we consider 8 Zone Panel	Please refer specification. Works to be carried out as per specification of BOQ.	BOQ	-No Change-
15	Page No.11, Part M, S.no.2 of Price Bid, Fire Fighting & Alarming Systems	Confirm the required materials for the Main Control Panel	Please refer specification. Works to be carried out as per specification of BOQ.	BOQ	-No Change-



16	Page No.11, Part M,S.no.3 of Price Bid, Fire Fighting & Alarming Systems	Can we consider Smoke detectors as lonisation detectors are banned from use.	Optical detector to be considered	Amendment to Part M , S.no.3, page no.11 of Price Bid: S/I/T/C breaking type typical smoke detector Optical type with LCD indicator -No Change-
17	Page No.11, Part M,S.no.3 of Price Bid, Fire Fighting & Alarming Systems	One Panel can support upto 2 Batteries only. Kindly confirm	Please refer BOQ specification. Works to be carried out as per specification of BOQ.	

R. A. ...
Manager (Technical)

Section Head (P & E Section)

Divisional Manager

Deputy General Manager

