

## **SUB: ADDENDUM/S & REPLY TO PRE-BID QUERIES**

## SELECTION OF MODULAR FURNITURE CONTRACTORS for INTERIOR FURNISHING WORKS AT GIFT CITY GANDHINAGAR

Si. No	Ref.	Query	Rank's reply/clarification
NO	General terms and conditions - Notice	1. ISO 18001:2007 (For Occupational Health and Safety Management System) has been officially withdrawn.	Bank's reply/clarification  1. Bidder should have ISO 45001:2018     certification instead of ISO 18001:2007.     Hence ISO 18001:2007 should be read     as ISO 45001:2018 throughout the     tender document.
1	inviting tenders - Eligibility criteria no. 5	<ul><li>2. OEM/OFM should have Oxislan 9810/1 Technology for power coating.</li><li>3. OEM shall have GREENGUARD or IGBC Certificate for their manufacturing facility.</li></ul>	<ol> <li>Existing certifications except mentioned above should continue as mentioned in the referred point.</li> <li>IGBC certification for product/company is not required. As we already preferred ISO certification in evalution criteria.</li> </ol>
2	General terms and conditions -general rules and directions to tenderers - point 27	Kindly clarify the value of stamp paper	Stamp paper of min. Rs. 100 will suffice.
		Can exemption against NSIC and MSME be taken?	1. As already stipulated in the tender document, MSME firms can be exempted from providing EMD provided, UDHYOG AADHAR certificate is submitted along with the tender document.
		<ul><li>2. Do we have to quote each item rate in a separate envelops for each item?</li><li>3. Does indemnity bond and integrity</li></ul>	<ul><li>2. No, the financial bid has to be placed in a separate single cover and the rates mentioned in numbers and words to be written in the space provided.</li><li>3. Yes, indemnity bond and integrity pact</li></ul>
		pact has to be provided along with technical bid?	has to be provided along with technical bid?
		4. Does tender form is also needed to be provided on stamp paper of appropriate value?	4. Not required.
3	General terms and conditions		

4.	General terms and conditions	As pre-bid meeting is on 24 <sup>th</sup> Aug, 2020 and last date of submission is 26 <sup>th</sup> August. Kindly extend the date for 15days.	Since, we have not received any pre-bid queries which require exhaustive study of the tender document, the extension of last date of submission is not required.  Further, since it is mandatory for the contractor to have a representative office in Ahmedabad/Gandhinagar, the delay in delivering the tender is ruled out. Hence, ANY TIME EXTENSION IN SUBMISSION OF TENDER IS NOT APPROVED.
5	General terms and conditions	The audited Balance sheet for the financial year 2019-20 cannot be provided since March onwards till June there has been a lockdown due to Covid 19, and still there are problems and therefore the MOF, GOI has extended the last date of submission of audited balance sheet till Nov 2020. However, we can provide self attested copy of Annual turnover along with the GSTR Returns filed as supporting document.	Self attested copy of Annual turnover along with the GSTR Returns filed as supporting document is to be provided. However, in cases where audited balance for FY19-20 cannot be provided, self attested copy of Annual turnover along with the GSTR Returns filed as supporting document is to be provided. Also, audited balance sheet of last 3 years i.e. 2016-17, 2017-18 and 2018-19 is required.
6	Technical Specifications: point: 14 BOQ item 3	Clarification in variation of size and make of pedestal.	Pedestal should be of size 405mm X 450mm X 650mm ht. Pre lam particle board should be used for the pedestal.
	Technical Specifications:	<ol> <li>Make of tiles</li> <li>In BOQ, L shape works stations are mentioned as 38no., where as in drawing the work station comes of out to be 34 in no. which of the quantities shall be considered for the quoting the price.</li> </ol>	<ol> <li>Tiles/panels should be of particle board.</li> <li>Quantities mentioned in the BOQ shall prevail over the drawings. However, the quantities may vary during the execution of work.</li> </ol>
7	point: 15 BOQ item 1&2	3. Height of raceway is provided as 100mm in BOQ where as in drawings, it is 150mm.	3. Height of raceway to be taken as 150mm.
8	Technical specifications	Color of Powder coating, Fabric and Back painted glass may be provided.	The color of powder coating, Fabric and Back painted glass will be provided only after finalization of the contractor and same is needed to be executed as per direction of the bank/architect without any additional cost.

## **ADDENDUM -1**

ONLY OEMs (Original Equipment Manufacturers), OFMs (Original Furniture Manufacturers) and their authorized dealers are permitted to participate in the bid.

ALL OTHER TERMS AND CONDITIONS OF THE TENDER DOCUMENT REMAIN UNCHANGED UNTILL FURTHER NOTIFICATION(S)

Place: Ahmedabad

SdDate: 24/08/2020 ASSISTANT GENERAL MANAGER